

[Home](#)[Bill Information](#)[California Law](#)[Publications](#)[Other Resources](#)[My Subscriptions](#)[My Favorites](#)Code: Section: [Up^](#)[Add To My Favorites](#)**HEALTH AND SAFETY CODE - HSC**

DIVISION 20. MISCELLANEOUS HEALTH AND SAFETY PROVISIONS [24000 - 27007] (*Division 20 enacted by Stats. 1939, Ch. 60.*)

CHAPTER 17. Air Duct Systems [25999- 25999.] (*Chapter 17 added by Stats. 1971, Ch. 382.*)

25999. If asbestos-containing materials are used in an air duct system which is installed in any building in the state on or after the effective date of this chapter, such material shall be overcoated with a sealant adequate to preclude erosion of asbestos fibers.

(*Added by Stats. 1971, Ch. 382.*)