

449.850 Facilities: Fire safety

1.

Portable multipurpose class ABC fire extinguishers are installed throughout the facility at the direction of the governmental entity that has jurisdiction over fire safety at the facility.

2.

Each portable fire extinguisher available at a facility is inspected, recharged and tagged at least once each year by a person certified by the State Fire Marshal to conduct such inspections.

3.

Each exit is maintained free of obstructions.

4.

Smoke detectors are installed at the facility at the direction of the governmental entity that has jurisdiction over fire safety at the facility and maintained operational.

5.

Smoking does not occur in the facility.

6.

An extinguishing receptacle approved by the governmental entity that has jurisdiction over fire safety at the facility is placed in each area on the premises of the facility where smoking is allowed.