

## **449.733 Electrical systems**

### **1.**

All electrical installations and systems must be tested to show that the equipment is installed and operates as planned or specified. A written record of tests on electrical systems and equipment must be supplied to the owner.

### **2.**

All spaces occupied by people, machinery and equipment within buildings, approaches to buildings and parking lots must have lighting. Rooms for patients must have general lighting. All switches for lighting in patient areas must operate quietly.

### **3.**

If fuel is stored for an emergency generator, the storage capacity must be sufficient for at least 24 hours of continuous operation.