

|->

Title 28@ HEALTH AND SAFETY

|->

Part IV@ Health Facilities

|->

Subpart C@ Long-Term Care Facilities

|->

Chapter 205@ PHYSICAL PLANT AND EQUIPMENT STANDARDS FOR LONG-TERM CARE NURSING FACILITIES

|->

Section 205.63@ Plumbing and piping systems required for existing and new construction

## **205.63 Plumbing and piping systems required for existing and new construction**

### **(a)**

Potable ice may not be manufactured or stored in the soiled utility room.

### **(b)**

Water distribution systems shall be designed and arranged to provide potable hot and cold water at hot and cold water outlets at all times. The system pressure shall be sufficient to operate fixture and equipment during maximum demand periods.

### **(c)**

Hot water outlets accessible to residents shall be controlled so that the water temperature of the outlets does not exceed 110°F.