

|->

Chapter 61@ DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

|->

Subchapter 61-17@ STANDARDS FOR LICENSING NURSING HOMES

|->

Sec2 61-17.2000@ FIRE PROTECTION EQUIPMENT AND SYSTEMS

|->

Section 61-17.2000.2001@ Fire Alarms and Sprinklers (II)

61-17.2000.2001 Fire Alarms and Sprinklers (II)

A.

A facility shall include a partial, manual, automatic, and supervised fire alarm system. A facility shall arrange the fire alarm system to transmit an alarm automatically to a third party by an approved method. A facility shall provide a fire alarm system that notifies all areas and floors of the building by audible and visual alarm. A facility shall provide a fire alarm system that shuts down central recirculating systems and outside air units that serve the area(s) of alarm origination as a minimum.

B.

A facility shall include all fire, smoke, heat, sprinkler flow, or manual fire alarming devices or systems that connect to the main fire alarm system and trigger the system when activated.

C.

A facility shall include a sprinkler system.

D.

A facility shall include a fire alarm pull station in or near each work station.