

|->

Chapter 61@ DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

|->

Subchapter 61-17@ STANDARDS FOR LICENSING NURSING HOMES

|->

Sec2 61-17.2400@ ELECTRICAL

|->

Section 61-17.2400.2404@ Receptacles (II)

61-17.2400.2404 Receptacles (II)

A.

A facility shall provide duplex grounding type receptacles in each resident room with one (1) duplex receptacle at the head of each bed in compliance with provisions of the codes officially adopted by the South Carolina Building Codes Council and the South Carolina Fire Marshal.

B.

Each resident bed location shall have a minimum of two (2) duplex receptacles.

C.

Each resident bed location shall be supplied by at least two (2) branch circuits.

D.

Duplex receptacles for general use shall be installed approximately fifty (50) feet apart in all corridors and within twenty-five (25) feet of the ends of corridors.