

## **388-97-3160 Night lights in new construction**

The nursing home must install in each resident room a night light that is:

**(1)**

Flush mounted on the wall;

**(2)**

Designed to prevent viewing the light source from thirty inches or more above the floor;

**(3)**

Located to provide safe pathway lighting for the staff and residents; and

**(4)**

Controlled by a switch at each resident room entrance door or by a master switch.