

388-97-3840 Walking surfaces in a new building or addition

The nursing must ensure that:

(1)

An abrupt change in the walking surface level including at door thresholds which are greater than one quarter inch are beveled to a one vertical in two horizontal; and

(2)

Changes in the walking surface level greater than one half inch are accomplished by means of a ramp with a maximum slope of one vertical in twelve horizontal.