

388-97-3460 Preinstallation submissions for new construction

The department of health, construction review, must receive and approve preinstallation submissions prior to installation. Preinstallation submissions may include any or all of the following:

(1)

Stamped shop drawings, hydraulic calculations, and equipment information sheets for fire sprinkler system(s);

(2)

Shop drawings, battery calculations, and equipment information sheets for fire detection and alarm systems;

(3)

Shop drawings and equipment information sheets for a kitchen hood and duct automatic fire extinguishing system;

(4)

Drawings and equipment information sheets for special egress control devices; and

(5)

Drawings and/or a finish schedule denoting areas to be carpeted with: (a) A coding system identifying type of carpet in each area; (b) A copy the manufacturer's specifications for each type of carpet; and (c) A copy of a testing

laboratory report of the radiant panel and smoke density tests for each type of carpet.

(a)

A coding system identifying type of carpet in each area;

(b)

A copy the manufacturer's specifications for each type of carpet; and

(c)

A copy of a testing laboratory report of the radiant panel and smoke density tests for each type of carpet.