

## **70647 Speech Pathology and/or Audiology Service Space**

### **(a)**

There shall be at least one two-room testing suite that meets Standard S-3.1, 1960 (R-1971), Criteria for Background Noise in Audiometer Rooms, of the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018.

### **(b)**

There shall be the space necessary for the tables and chairs to conduct interviews, consultations, treatment and to accommodate patients in wheelchairs or on stretchers.