

**A-0718**

**(Rev. 200, Issued: 02-21-20; Effective: 02-21-20, Implementation: 02-21-20)**

**§482.41(b)(9) Buildings must have an outside window or outside door in every sleeping room, and for any building constructed after July 5, 2016 the sill height must not exceed 36 inches above the floor. Windows in atrium walls are considered outside windows for the purposes of this requirement.**

- (i) The sill height requirement does not apply to newborn nurseries and rooms intended for occupancy for less than 24 hours.**
- (ii) The sill height in special nursing care areas of new occupancies must not exceed 60 inches.**

**Interpretive Guidelines §482.41(b)(9):**

Guidance is pending and will be updated in future release.