

A-0717

(Rev. 200, Issued: 02-21-20; Effective: 02-21-20, Implementation: 02-21-20)

§482.41(b)(8) When a sprinkler system is shut down for more than 10 hours, the hospital must:

- (i) Evacuate the building or portion of the building affected by the system outage until the system is back in service, or**
- (ii) Establish a fire watch until the system is back in service.**

Interpretive Guidelines §482.41(b)(8):

Guidance is pending and will be updated in future release.