

## **60301.320 Filtered Wastewater**

"Filtered wastewater" means an oxidized wastewater that meets the criteria in subsection (a) or (b):

### **(a)**

Has been coagulated and passed through natural undisturbed soils or a bed of filter media pursuant to the following: (1) At a rate that does not exceed 5 gallons per minute per square foot of surface area in mono, dual or mixed media gravity, upflow or pressure filtration systems, or does not exceed 2 gallons per minute per square foot of surface area in traveling bridge automatic backwash filters; and (2) So that the turbidity of the filtered wastewater does not exceed any of the following: (A) An average of 2 NTU within a 24-hour period; (B) 5 NTU more than 5 percent of the time within a 24-hour period; and (C) 10 NTU at any time.

### **(1)**

At a rate that does not exceed 5 gallons per minute per square foot of surface area in mono, dual or mixed media gravity, upflow or pressure filtration systems, or does not exceed 2 gallons per minute per square foot of surface area in traveling bridge automatic backwash filters; and

### **(2)**

So that the turbidity of the filtered wastewater does not exceed any of the following:

(A) An average of 2 NTU within a 24-hour period; (B) 5 NTU more than 5 percent of the time within a 24-hour period; and (C) 10 NTU at any time.

**(A)**

An average of 2 NTU within a 24-hour period;

**(B)**

5 NTU more than 5 percent of the time within a 24-hour period; and

**(C)**

10 NTU at any time.

**(b)**

Has been passed through a microfiltration, ultrafiltration, nanofiltration, or reverse osmosis membrane so that the turbidity of the filtered wastewater does not exceed any of the following: (1) 0.2 NTU more than 5 percent of the time within a 24-hour period; and (2) 0.5 NTU at any time.

**(1)**

0.2 NTU more than 5 percent of the time within a 24-hour period; and

**(2)**

0.5 NTU at any time.