

60313 General Requirements

(a)

No person other than a recycled water agency shall deliver recycled water to a dual-plumbed facility.

(b)

Except as allowed pursuant to section 13553(d) of the Water Code, a recycled water agency shall not deliver recycled water for any internal use to any individually-owned residential units including free-standing structures, multiplexes, or condominiums.

(c)

No recycled water agency shall deliver recycled water for internal use except for fire suppression systems, to any facility that produces or processes food products or beverages. For purposes of this Subsection, cafeterias or snack bars in a facility whose primary function does not involve the production or processing of foods or beverages are not considered facilities that produce or process foods or beverages.

(d)

No recycled water agency shall deliver recycled water to a facility using a dual plumbed system unless the report required pursuant to section 13522.5 of the Water Code, and which meets the requirements set forth in section 60314, has been submitted to, and approved by, the regulatory agency.