

## **60335 Alarms**

### **(a)**

Alarm devices required for various unit processes as specified in other sections of these regulations shall be installed to provide warning of: (1) Loss of power from the normal power supply. (2) Failure of a biological treatment process. (3) Failure of a disinfection process. (4) Failure of a coagulation process. (5) Failure of a filtration process. (6) Any other specific process failure for which warning is required by the regulatory agency.

#### **(1)**

Loss of power from the normal power supply.

#### **(2)**

Failure of a biological treatment process.

#### **(3)**

Failure of a disinfection process.

#### **(4)**

Failure of a coagulation process.

#### **(5)**

Failure of a filtration process.

#### **(6)**

Any other specific process failure for which warning is required by the regulatory agency.

**(b)**

All required alarm devices shall be independent of the normal power supply of the reclamation plant.

**(c)**

The person to be warned shall be the plant operator, superintendent, or any other responsible person designated by the management of the reclamation plant and capable of taking prompt corrective action.

**(d)**

Individual alarm devices may be connected to a master alarm to sound at a location where it can be conveniently observed by the attendant. In case the reclamation plant is not attended full time, the alarm(s) shall be connected to sound at a police station, fire station or other full-time service unit with which arrangements have been made to alert the person in charge at times that the reclamation plant is unattended.