California Code Of Regulations
|->
Title 22@ Social Security
|->
Division 4@ Environmental Health
|->
Chapter 3@ Water Recycling Criteria
|->
Article 10@ Alternative Reliability Requirements for Uses Requiring Oxidized, Disinfected Wastewater or Oxidized, Coagulated, Clarified, Filtered, Disinfected Wastewater
|->

60351 Filtration

All filtration unit processes shall be provided with one of the following reliability features:

(a)

Section 60351@ Filtration

Alarm and multiple filter units capable of treating the entire flow with one unit not in operation.

(b)

Alarm, short-term retention or disposal provisions and standby replacement equipment.

(c)

Alarm and long-term storage or disposal provisions.

(d)

Automatically actuated long-term storage or disposal provisions.

(e)

Alarm and standby filtration unit process.