```
California Code Of Regulations
|->
Title 22@ Social Security
|->
Division 4@ Environmental Health
|->
Chapter 3@ Water Recycling Criteria
|->
Article 10@ Alternative Reliability Requirements for Uses Requiring Oxidized, Disinfected Wastewater or Oxidized, Coagulated, Clarified, Filtered, Disinfected Wastewater
|->
Section 60349@ Coagulation
```

## 60349 Coagulation

## (a)

All coagulation unit processes shall be provided with the following mandatory features for uninterrupted coagulant feed:(1) Standby feeders, (2) Adequate chemical stowage and conveyance facilities, (3) Adequate reserve chemical supply, and (4) Automatic dosage control.

**(1)** 

Standby feeders,

(2)

Adequate chemical stowage and conveyance facilities,

(3)

Adequate reserve chemical supply, and

(4)

Automatic dosage control.

## (b)

All coagulation unit processes shall be provided with one of the following reliability features:(1) Alarm and multiple coagulation units capable of treating the entire flow with one unit not in operation; (2) Alarm, short-term retention or disposal provisions, and standby replacement equipment; (3) Alarm and long-term storage or disposal provisions; (4) Automatically actuated long-term storage or disposal provisions, or (5) Alarm and standby coagulation process.

(1)

Alarm and multiple coagulation units capable of treating the entire flow with one unit not in operation;

(2)

Alarm, short-term retention or disposal provisions, and standby replacement equipment;

(3)

Alarm and long-term storage or disposal provisions;

(4)

Automatically actuated long-term storage or disposal provisions, or

(5)

Alarm and standby coagulation process.