California Code Of Regulations
|->
Title 22@ Social Security
|->
Division 4@ Environmental Health
|->
Chapter 3@ Water Recycling Criteria
|->
Article 10@ Alternative Reliability Requirements for Uses Requiring Oxidized, Disinfected Wastewater or Oxidized, Coagulated, Clarified, Filtered, Disinfected Wastewater

## **60343 Primary Treatment**

All primary treatment unit processes shall be provided with one of the following reliability features:

## (a)

Section 60343@ Primary Treatment

Multiple primary treatment units capable of producing primary effluent with one unit not in operation.

## (b)

Standby primary treatment unit process.

## (c)

Long-term storage or disposal provisions.