

64255 Surveillance

(a)

A local primacy agency shall establish and maintain an inventory of all small water systems under its jurisdiction. The inventory shall be updated at least annually and shall include the following information for each system: (1) All of the information specified in section 64252(a)(6); (2) The name and telephone number of the operator of any treatment facilities utilized by the system; and (3) A copy of the current emergency notification plan required pursuant to section 116460 of the Health and Safety Code.

(1)

All of the information specified in section 64252(a)(6);

(2)

The name and telephone number of the operator of any treatment facilities utilized by the system; and

(3)

A copy of the current emergency notification plan required pursuant to section 116460 of the Health and Safety Code.

(b)

A local primacy agency shall conduct a routine inspection of each small water system within its jurisdiction as follows: (1) At least once every two years on each small water system utilizing a surface water source as defined in section

64651.10; (2) At least once every two years on each small water system utilizing groundwater that is treated in order to meet drinking water standards; and (3) At least once every five years on each small water system utilizing groundwater without treatment.

(1)

At least once every two years on each small water system utilizing a surface water source as defined in section 64651.10;

(2)

At least once every two years on each small water system utilizing groundwater that is treated in order to meet drinking water standards; and

(3)

At least once every five years on each small water system utilizing groundwater without treatment.

(c)

A local primacy agency shall conduct a sanitary survey of each small water system within its jurisdiction at least once every five years. A sanitary survey may be conducted in lieu of any routine inspection.

(d)

A local primacy agency shall identify any deficiencies found during the routine inspection or sanitary survey and shall submit a follow-up notice to the small water system describing such deficiencies and prescribing a time schedule for corrective action. The notice shall be sent to the small water system within 60 days of the routine inspection or sanitary survey.

(e)

A local primacy agency shall complete a routine inspection or sanitary survey report for each routine inspection or sanitary survey conducted within 90 days of

completion of the sanitary survey or routine inspection.

(f)

A local primacy agency shall determine which small water systems under its jurisdiction utilize surface water or groundwater under the direct influence of surface water and are subject to surface water treatment requirements as specified in section 64650.