

## **64418.8 Compliance**

### **(a)**

A public water system using POU's in lieu of centralized treatment shall be in violation of an MCL if: (1) for all POU's combined, during a 12-month interval, more than five percent (5%) of the results of the effluent monitoring conducted pursuant to section 64418.5 exceed an MCL; (2) for a POU, the effluent fails to meet the MCL, which is determined in accordance with the applicable compliance determination requirements in this Title. Depending on the contaminant and concentration detected, compliance determination may be based on the result of a single sample, an initial sample averaged with one or two confirmation sample(s), or an average of four quarterly or six monthly samples; or (3) a building or dwelling unit served by the water system does not have a POU installed pursuant to this Article.

### **(1)**

for all POU's combined, during a 12-month interval, more than five percent (5%) of the results of the effluent monitoring conducted pursuant to section 64418.5 exceed an MCL;

### **(2)**

for a POU, the effluent fails to meet the MCL, which is determined in accordance with the applicable compliance determination requirements in this Title. Depending on the contaminant and concentration detected, compliance determination may be based on

the result of a single sample, an initial sample averaged with one or two confirmation sample(s), or an average of four quarterly or six monthly samples; or

**(3)**

a building or dwelling unit served by the water system does not have a POU installed pursuant to this Article.