

|-&gt;

Title 22@ Social Security

|-&gt;

Division 4@ Environmental Health

|-&gt;

Chapter 15@ Domestic Water Quality and Monitoring Regulations

|-&gt;

Article 3@ Primary Standards-Bacteriological Quality

|-&gt;

Section 64426.6@ Coliform Treatment Technique

## **64426.6 Coliform Treatment Technique**

### **(a)**

A public water system is in violation of the coliform treatment technique when either of the following occurs: (1) The system exceeds a treatment technique trigger specified in Section 64426.7 and then fails to conduct the required assessment or corrective actions within the timeframe specified in Section 64426.8; or (2) A seasonal system fails to complete a State Board-approved start-up procedure prior to serving water to the public.

#### **(1)**

The system exceeds a treatment technique trigger specified in Section 64426.7 and then fails to conduct the required assessment or corrective actions within the timeframe specified in Section 64426.8; or

#### **(2)**

A seasonal system fails to complete a State Board-approved start-up procedure prior to serving water to the public.

### **(b)**

A public water system in violation of the coliform treatment technique shall notify the State Board by the end of the next business day on which this is determined. The system shall also notify the public pursuant to Sections 64463, 64463.4, and 64465.

### **(c)**

A public water system in violation of the reporting requirement in subsection (b) to notify the State Board shall notify the public pursuant to Sections 64463, 64463.7, and 64465.