

## **64433.7 Recordkeeping, Reporting, and Notification for Water Systems Fluoridating**

### **(a)**

By the tenth day of each month following the month being reported, each water supplier fluoridating its water supply shall send operational reports to the State Board, which include the following: (1) The fluoride compounds used and the calculated fluoride dose in mg/L; (2) Information on any interruptions in the fluoridation treatment which may have occurred during the month including the duration of the interruptions, an explanation of causes, and what corrective actions were taken to insure that fluoridation treatment was resumed in a timely manner; (3) The results of the daily monitoring for fluoride in the water distribution system, reported in terms of daily results, and ranges and the number of samples collected; and (4) The results of monthly split sample(s) analyzed pursuant to Section 64433.3(c).

### **(1)**

The fluoride compounds used and the calculated fluoride dose in mg/L;

### **(2)**

Information on any interruptions in the fluoridation treatment which may have occurred during the month including the duration of the interruptions, an explanation of causes, and what corrective actions were taken to insure that fluoridation treatment was resumed in a timely manner;

**(3)**

The results of the daily monitoring for fluoride in the water distribution system, reported in terms of daily results, and ranges and the number of samples collected; and

**(4)**

The results of monthly split sample(s) analyzed pursuant to Section 64433.3(c).

**(b)**

For water systems that fluoridated the previous fiscal year (July 1 through June 30), the water supplier shall report the operations and maintenance costs for that year to the State Board by August 1.

**(c)**

Whenever a water system initiates fluoridation, suspends fluoridation for more than ninety days, or reinitiates fluoridation after a suspension of more than ninety days, the water supplier shall notify the consumers, local health departments, pharmacists, dentists, and physicians in the area served by the water system, regarding the status of the fluoridation treatment. If a water system with more than one fluoridation system suspends the use of one or more of its fluoridation systems, but the level of fluoride being served to the consumers is in conformance with Table 64433.2-A, no notification shall be required.

**(d)**

If a fluoride overfeed exceeding 10.0 mg/L occurs, the water system shall notify the State Board by the end of the business day of the occurrence or within 24 hours if the State Board office is closed.

**(e)**

If the level of fluoride in the distribution system is found to be less than the control range in Table 64433.2-A in two or more samples in a month, the water

system shall notify the State Board within three business days of the second occurrence. If the level of fluoride in the distribution system is found to be 0.1 mg/L or more above the control range up to 10.0 mg/L, the water supplier shall notify the State Board within three business days of the occurrence.