

64448 Treatment Technique Requirements

(a)

A public water system which uses acrylamide and/or epichlorohydrin in drinking water treatment shall certify annually in writing to the State Board that the

combination of dose and monomer does not exceed the following levels: (1)

Acrylamide 0.05% monomer in polyacrylamide dosed at 1 mg/L, or equivalent. (2) Epichlorohydrin 0.01% residual of epichlorohydrin dosed at 20 mg/L, or equivalent.