

|->

Title 22@ Social Security

|->

Division 4@ Environmental Health

|->

Chapter 15@ Domestic Water Quality and Monitoring Regulations

|->

Article 16@ Secondary Drinking Water Standards

|->

Section 64449.4@ Use of Sources that Exceed a Secondary MCL and DO Not Have a Waiver

64449.4 Use of Sources that Exceed a Secondary MCL and DO Not Have a Waiver

A source that exceeds one or more of the secondary MCLs in Table 64449-A and does not have a waiver may be used only if the source meets the requirements in Section 64414 , and the community water system:

(a)

Meters the source's monthly production and submits the results to the State Board by the 10th day of the next month;

(b)

Counts any part of a day as a full day for purposes of determining compliance with Section 64414(c);

(c)

As a minimum, conducts public notification by including information on the source's use (dates, constituent levels, and reasons) in the Consumer Confidence Report (Sections 64480 through 64483);

(d)

Provides public notice prior to use of the source by electronic media, publication in a local newspaper, and/or information in the customer billing, if the situation is such that the water system can anticipate the use of the source (e.g., to perform water system maintenance); and

(e)

Takes corrective measures such as flushing after the source is used to minimize any residual levels of the constituent in the water distribution system.