

## **64573 Minimum Water Main Size for Community Water Systems**

Newly installed water mains in a community water system shall have a nominal diameter of at least four inches.