

64663 State Board Notification

A supplier shall notify the State Board as soon as possible, but no later than by the end of the next business day, or within 24 hours, whichever is less, by telephone or other equally rapid means whenever:

(a)

A combined filter effluent turbidity exceedance occurs pursuant to table 64663:

Table 64663 Combined Filter Effluent Turbidity Exceedances Requiring State Board

Notification If a supplier uses...And the turbidity of the combined filter effluent

monitored and recorded pursuant to section 64655... (1) Any filtration

technology pursuant to section 64653 Exceeds 5.0 NTU at any time. (2)

Conventional or direct filtration treatment and serves 10,000 or more persons(A)

Exceeds 1 NTU for more than one continuous hour; (B) Exceeds 1 NTU at

four-hour intervals; or (C) Exceeds 1.0 NTU for more than eight consecutive

hours. (3) Conventional or direct filtration treatment and serves fewer than

10,000 persons(A) For a supplier using a grab sample monitoring program: 1.

Exceeds 1 NTU; or 2. Exceeds 1.0 NTU in more than two consecutive samples

taken every four hours; and (B) For a supplier using a continuous monitoring

program: 1. If recording results at least once every 15 minutes, equals paragraph

(2)(A); or 2. Equals paragraph (2)(B) or (2)(C). (4) Diatomaceous earth or slow

sand filtrationExceeds 1.0 NTU in more than two consecutive samples taken every

four hours. (5) An alternative filtration technology pursuant to section 64653

Exceeds the maximum performance standard established pursuant to sections 64653(e), (f), (g), and (h).

(b)

There is a failure to maintain a minimum disinfectant residual of 0.2 mg/L in the water being delivered to the distribution system. The supplier shall report whether or not the disinfectant residual was restored to at least 0.2 mg/L within four hours.

(c)

An event occurs which may affect the ability of the treatment plant to produce a safe, potable water including but not limited to spills of hazardous materials in the watershed and unit treatment process failures.

(d)

For a supplier avoiding filtration, the turbidity immediately prior to the first or only point of disinfectant application exceeds 5 NTU.

(e)

A supplier discovers the occurrence of an acute infectious illness that may be potentially attributable to the water system.