

64669.105 Cross-Connection Control

(a)

A cross-connection control survey and hazard assessment of the water treatment plants and other facilities included in the DPR project that treat, store, convey, or distribute DPR project water shall be conducted to protect the DPR project water and facilities from contamination or pollution from on-site hazards. The initial survey and hazard assessment shall be completed within one year of the start of full-scale operation, and subsequent surveys and hazard assessments shall be completed annually thereafter.

(b)

A DiPRRA shall compile the reports of the cross-connection control surveys and hazard assessments for each DPR project facility and make the reports available to the State Board upon request.