

64669.10 General Requirements

(a)

The source water for a DPR project shall be municipal wastewater.

(b)

There shall be no bypass constructed around required treatment processes for municipal wastewater from the DPR project to the distribution system.

(c)

A DiPRRA shall enable and facilitate the inspection by the State Board at any time of all facilities, operations, and records used to comply with the requirements in this Article as described in the engineering report including facilities and operations related to: (1) Source(s) and treatment; (2) Wastewater source control pursuant to section 64669.40; (3) Cross-connection control pursuant to section 64669.105; (4) Technical, managerial, and financial capacity demonstration pursuant to section 64669.30; and (5) Operations plan, monitoring plan, and water safety plan pursuant to sections 64669.80, 64669.90, and 64669.55, respectively.

(1)

Source(s) and treatment;

(2)

Wastewater source control pursuant to section 64669.40;

(3)

Cross-connection control pursuant to section 64669.105;

(4)

Technical, managerial, and financial capacity demonstration pursuant to section 64669.30; and

(5)

Operations plan, monitoring plan, and water safety plan pursuant to sections 64669.80, 64669.90, and 64669.55, respectively.