

|->

Title 22@ Social Security

|->

Division 4@ Environmental Health

|->

Chapter 17.5@ Lead and Copper

|->

Article 3@ Monitoring for Lead and Copper

|->

Section 64675@ General Requirements for Tap Sampling for Lead and Copper

64675 General Requirements for Tap Sampling for Lead and Copper

(a)

During each period, each system shall conduct standard tap sampling by collecting one sample from the number of sites based on the number of people served specified in table 64675-A under Standard Tap Sampling.

(b)

During each period, each system conducting reduced tap sampling shall collect at least one sample from the number of sites based on the number of people served specified in table 64675-A under Reduced Tap Sampling, as follows: (1) The sites shall be representative of the sites required for standard tap sampling. (2) The samples shall be collected during the months of June, July, August, or September, unless the Department approves an alternate set of four months based on a review of the system's operations and lead and copper data, in which case the system shall initiate sampling during the alternate set of four months when directed in writing to do so by the Department, as follows: (A) No later than 21 months after the previous period, if sampling annually, or (B) No later than 45 months after the previous period, if sampling triennially. Table 64675-A Lead and Copper Tap Sampling Sites

System Size	Standard Tap Sampling	Reduced Tap Sampling
(Minimum Number of Sites)	>100,000	10050
10,001 to 100,000	60	30
3,301 to 10,000	40	20
501 to 3,300	20	10
101 to 500	10	5
<101	5	5

(1)

The sites shall be representative of the sites required for standard tap sampling.

(2)

The samples shall be collected during the months of June, July, August, or September, unless the Department approves an alternate set of four months based on a review of the system's operations and lead and copper data, in which case the system shall initiate sampling during the alternate set of four months when directed in writing to do so by the Department, as follows: (A) No later than 21 months after the previous period, if sampling annually, or (B) No later than 45 months after the previous period, if sampling triennially. Table 64675-A Lead and Copper Tap Sampling Sites System SizeStandard Tap SamplingReduced Tap Sampling (Minimum Number of Sites)

>100,000	10,001 to 100,000	6030	3,301 to 10,000	4020	501 to 3,300	2010	101 to 500	105	<101	55
----------	-------------------	------	-----------------	------	--------------	------	------------	-----	------	----

(A)

No later than 21 months after the previous period, if sampling annually, or

(B)

No later than 45 months after the previous period, if sampling triennially. Table 64675-A Lead and Copper Tap Sampling Sites System SizeStandard Tap SamplingReduced Tap Sampling (Minimum Number of Sites) >100,00010050 10,001 to 100,0006030 3,301 to 10,0004020 501 to 3,3002010 101 to 500105 <10155

(c)

Sample sites shall be selected pursuant to section 64676 (Sample Site Selection).