

64679 Supplemental Monitoring

A water system with a lead action level exceedance shall offer to sample the tap water of any customer who requests it. The system is not required to pay for collecting or analyzing the sample.