

64681 Initial WQP Monitoring

For initial WQP monitoring, each system shall monitor for the following WQPs, pursuant to section 64680 (General WQP Monitoring Requirements):

(a)

pH;

(b)

Alkalinity;

(c)

Orthophosphate, when an inhibitor containing a phosphate compound is used;

(d)

Silica, when an inhibitor containing a silicate compound is used;

(e)

Calcium;

(f)

Conductivity; and

(g)

Water temperature.