

|->

Title 22@ Social Security

|->

Division 4.5@ Environmental Health Standards for the Management of Hazardous Waste

|->

Chapter 14@ Standards for Owners and Operators of Hazardous Waste Transfer, Treatment, Storage, and Disposal Facilities

|->

Article 10@ Tank Systems

|->

Section 66264.190@ Applicability

66264.190 Applicability

The requirements of this article apply to owners and operators of facilities that use tank systems for transferring, storing or treating hazardous waste except as otherwise provided in subsections (a), (b) and (c) of this section or in section 66264.1 of this chapter.

(a)

Tank systems that are used to transfer, store or treat hazardous waste which contains no free liquids and are situated inside a building with an impermeable floor are exempted from the requirements in section 66264.193. To demonstrate the absence or presence of free liquids in the transferred/stored/treated waste, EPA Method 9095 (Paint Filter Liquids Test) as described in "Test Methods for Evaluating Solid Wastes, Physical/Chemical Methods" (EPA Publication No. SW-846 Third Edition and Updates, (incorporated by reference in section 66260.11 of this chapter) shall be used.

(b)

Tank systems, including sumps, as defined in section 66260.10, that serve as part of a secondary containment system to collect or contain releases of hazardous wastes are exempted from the requirements in section 66264.193(a) of this article.

(c)

Tanks, sumps, and other such collection devices or systems used in conjunction

with drip pads, as defined in 66260.10 of this chapter and regulated under Chapter 14, Article 15.7, shall meet the requirements of this article.