

|-&gt;

Title 22@ Social Security

|-&gt;

Division 4.5@ Environmental Health Standards for the Management of Hazardous Waste

|-&gt;

Chapter 14@ Standards for Owners and Operators of Hazardous Waste Transfer, Treatment, Storage, and Disposal Facilities

|-&gt;

Article 28@ Air Emission Standards for Equipment Leaks

|-&gt;

Section 66264.1056@ Standards: Open-Ended Valves or Lines

## **66264.1056 Standards: Open-Ended Valves or Lines**

### **(a)**

(1) Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve. (2) The cap, blind flange, plug, or second valve shall seal the open end at all times except during operations requiring hazardous waste stream flow through open-ended valve or line.

#### **(1)**

Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve.

#### **(2)**

The cap, blind flange, plug, or second valve shall seal the open end at all times except during operations requiring hazardous waste stream flow through open-ended valve or line.

### **(b)**

Each open-ended valve or line equipped with a second valve shall be operated in a manner such that the valve on the hazardous waste stream end is closed before the second valve is closed.

### **(c)**

When a double block and bleed system is being used, the bleed valve or line may remain open during operations that require venting the line between the block valves but shall comply with subsection (a) of this section at all other times.