

66265.176 Special Requirements for Ignitable or Reactive Waste

Containers holding ignitable or reactive waste shall be located at least 15 meters (50 feet) from the facility's property line.