

66265.260 Monitoring and Inspection

An owner or operator required to have a leak detection system under section 66265.254 shall record the amount of liquids removed from each leak detection system sump at least once each week during the active life and closure period.