

75063 Water Supply and Plumbing

(a)

Where water for human consumption is obtained from an independent source, it shall be subjected to bacteriological analysis by the local health department, the Department or a licensed commercial laboratory at least every three months. A copy of the most recent laboratory report shall be available for inspection.

(b)

Plumbing and drainage facilities shall be maintained in compliance with Chapter 1, Division T17, Title 24, California Administrative Code.