

§ 76667. Mechanical Systems.

(a) Heating, air conditioning and ventilating systems shall be maintained in normal operating conditions to provide a comfortable temperature. These systems shall meet the construction requirements of Title 24 of the California Administrative Code in effect at the time plans were approved for the facility.

(b) Temperature and humidity shall be maintained within a normal comfort range by heating, air conditioning or other means. The heating apparatus employed shall not constitute a burn hazard to the clients.

Note: Authority cited: Section 208(a), Health and Safety Code. Reference: Section 1276, Health and Safety Code.

22 CCR § 76667, 22 CA ADC § 76667