California Code Of Regulations
|->
Title 22@ Social Security
|->
Division 5@ Licensing and Certification of Health Facilities, Home Health Agencies, Clinics, and Referral Agencies
|->
Chapter 11@ Chemical Dependency Recovery Hospital Licensing Regulations
|->
Article 5@ Administration

79341 Fire and Internal Disasters

(a)

|->

Section 79341@ Fire and Internal Disasters

A written fire and internal disaster program, incorporating evacuation procedures, shall be developed with the assistance of fire, safety and other appropriate experts and shall be implemented. A copy of the program shall be available on the premises for review by the Department.

(b)

The written program shall include at least the following: (1) Plans for the assignment of personnel to specific tasks and responsibilities. (2) Instructions relating to the use of alarm systems and signals. (3) Information concerning methods of fire containment. (4) Systems for notification of appropriate persons. (5) Information concerning the location of fire fighting equipment. (6) Specification of evacuation routes and procedures. (7) Other provisions as the local situation dictates.

(1)

Plans for the assignment of personnel to specific tasks and responsibilities.

(2)

Instructions relating to the use of alarm systems and signals.

(3)

Information concerning methods of fire containment.

(4)

Systems for notification of appropriate persons.

(5)

Information concerning the location of fire fighting equipment.

(6)

Specification of evacuation routes and procedures.

(7)

Other provisions as the local situation dictates.

(c)

Fire and internal disaster drills shall be held at least quarterly for each shift of CDRH personnel and under varied conditions. The actual evacuation of patients to safe areas during a drill is optional.

(d)

The evacuation plan shall be posted throughout the CDRH and shall include at least the following: (1) Evacuation routes. (2) Location of fire alarm boxes. (3) Location of fire extinguishers.

(1)

Evacuation routes.

(2)

Location of fire alarm boxes.

(3)

Location of fire extinguishers.